

## TYPE APPROVAL CERTIFICATE

## This is to certify:

That the Fire Detector

with type designation(s)

**SOC-E3NM, SOC-E3NM(WHT), DCD-CE3M, DCD-AE3M, DRD-EM, DCD-1E-IS, DCD-1E-IS(WHT), YBN-R/6M, YBN-R/6M(WHT), YBN-R/4IS, YBN-R/4IS(WHT), MBB-1, MBB-1(WHT), MBB-2, MBB-2(WHT)**

Issued to

**Hochiki Europe (UK) Ltd.**  
**London, United Kingdom**

is found to comply with

**DNV GL rules for classification – Ships****IMO International Code for Fire Safety Systems (FSS Code) Chapter 9**

## Application :

**Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.****Temperature B****Humidity B****Vibration A****EMC B****Enclosure Required protection according to the Rules shall be provided upon installation on board.**Issued at **Hamburg** on **2020-02-20**for **DNV GL**This Certificate is valid until **2025-02-19**.DNV GL local station: **Southampton**Approval Engineer: **Heinz Scheffler**

---

**Joannis Papanuskas**  
**Head of Section**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Job Id: **262.1-025949-2**  
Certificate No: **TAA00001MF**  
Revision No: **1**

## Product description

### Conventional Smoke Detector:

SOC-E3NM: Conventional Photoelectric Smoke Detector  
SOC-E3NM (WHT): Conventional Photoelectric Smoke Detector (White)

### Conventional Heat Detector:

DCD-CE3M: Conventional high temperature heat detector  
DCD-AE3M: Conventional heat detector  
DCD-1E-IS: Intrinsically safe conventional rate of rise heat detector  
DCD-1E-IS (WHT): Intrinsically safe conventional rate of rise heat detector (White)

### Conventional Flame Detector:

DRD-EM: Conventional flame detector

### Base:

YBN-R/6M: Standard mounting base  
YBN-R/6M (WHT): Standard mounting base (White)  
YBN-R/4IS: Intrinsically Safe Mounting Base  
YBN-R/4IS(WHT): Intrinsically Safe Mounting Base (White)  
MBB-1: Marine back box  
MBB-1 (WHT): Marine back box (White)  
MBB-2: Marine back box  
MBB-2 (WHT): Marine back box (White)

## Application/Limitation

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNVGL, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNVGL Rules for Ships Pt.4 Ch.9 Control and Monitoring Systems.

Ex-certification is not covered by this certificate. Application in hazardous area to be approved in each case according to the Rules and Ex-Certification/ Special Condition for Safe Use listed in valid Ex-certificate issued by a notified/recognized Certification Body

## Type Approval documentation

**Test Reports:** TE-P103234, P103234-1001-SW, 103070255LHD-002, 103070255LHD-021, 103925944LHD-001i, 210418, TE 225596, P108884, TE94410, 103437212LHD-002a, 104050159LHD-041, 104050159LHD-001a, 104050159LHD-001b, 104050159LHD-001c, TE255345, TE255345a, P102507, 103437212LHD-021, TE296268, 104050159LHD-001d

### Documents:

General Assembly & Circuit Diagrams:

HA-01-592, HA-01-590, 7-0-000-3862-721, 7-0-000-0005-721, 7-0-000-3868-721, 7-0-000-0006-721, 2-1-0-051, 1217170-00, 7-0-000-1916-721, 7-0-000-1958-721, 1226350-00, 1226370-00

Installation Instructions:

2-3-0-500, 2-3-0-345

Product Specification (Datasheets):

SOC-E3NM, DCD-AE3M, DCD-CE3M, DCD-1E-IS, DRD-EM,

Job Id: **262.1-025949-2**  
Certificate No: **TAA00001MF**  
Revision No: **1**

### Tests carried out

Applicable tests according to class guideline DNVGL-CG-0339, December 2019; EN 54-5 (2000) /A1(2002), EN 54-7 (2000)/A1(2002)/A2(2006), EN 54-10 (2002)/A1(2005), IEC 60092-504 (2016)

### Marking of product

The products to be marked with:

- Model name
- Manufacturer name
- Serial number

### Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE