



	MM01-E JT1
1	Relay 1 NC Lamp Fault
2	Relay 2 NC Power+Sys Fault
3	COM Relay 1+2
4	In1 mute buzzer
5	In2 ext. switch special function
6	Input GND
7	24V out for In 1+2
8	GND out for In 1+2

	DATE	NAME	YARD	SHIP NAME				FORMAT
DESIGN	2015-06-09	Kaul			B	Device Tags added	04.03.2020	AKL A2
CHECK	2015-07-02	Kruse		BUILD NO	A	wiring changed	03.09.2019	AK SCALE
APPR	2015-07-02	Kruse			REV	KIND OF LAST ALTERATION	DATE	NAME +/-
 DECKMA GmbH Decksmaschinen und Automation Vertriebs GmbH				DESIGNATION				
				NLS3000 24V DC (8 Channel) internal wiring and external connection				
				DRAWING NO.				Sheet
				S5934				1/1